



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

MAY 31 1984

MEMORANDUM

SUBJECT: Classification of Wells Injecting Treated Stream
from Secondary Waste Water Treatment Plant, Commonly
Called Secondary Effluent - Region II.
UIC Well Classification Advisory #2

FROM: Thomas E. Belk, Chief, *Thomas E. Belk*
Ground Water Protection Branch
Office of Drinking Water

TO: Peter A. Acker, Chief,
Ground Water Protection Section
Region II

We are responding to your telephone request that we concur on your classification of wells injecting secondary effluent as Class V wells. Presuming that the stream does not contain any hazardous waste not removed by the treatment process, then the wells are classified as Class I if they inject below the lowest Underground Source of Drinking Water, and Class V if they inject into or above a USDW. We realize this does not agree with your request, but it is the classification scheme contained in the regulations.

3085